

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3774-0923:0101

Page 1 of 1

CATEGORY: 3774 -- ELECTRIC LOCKS

LISTEE: SECURITRON MAGNALOCK550 Vista Blvd, Sparks, NV 89434
Contact: Erik Strauss (775) 355-5625 Fax (775) 355-5638
Email: eriks@securitron.com

DESIGN: Models Series 32, 34, *38, 62, *68, 82 SAM and SAM2 exit locks with suffix -C, -DV, -S, -L, -F or -G. Unit consists of a lock assembly, door mounting hardware and means for connecting to a remote control circuit. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as electromagnetic locks for use on non-rated door assemblies to prevent unauthorized entry when the building is unoccupied. Authority having jurisdiction shall be consulted prior to installation.

NOTE:

*Rev. 04-19-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division